

消 防 處  
牌 照 及 審 批 總 區  
消 防 工 程 合 規 課  
通 風 系 統 組

香港灣仔告士打道 5 號稅務大樓 35 樓



**FIRE SERVICES DEPARTMENT**  
**LICENSING & CERTIFICATION COMMAND**  
Fire Protection Engineering Compliance Division  
Ventilating Systems Group  
35/F, Revenue Tower,  
5 Gloucester Road, Wan Chai, Hong Kong

本處檔號 Our Ref.: FSD LC VSG 317/21  
來函檔號 Your Ref.:  
圖文傳真 Fax: (852) 2382 2495  
電 話 Tel. No.: (852) 2718 7567  
電 郵 E-mail: fsvs@hkfsd.gov.hk

20 August 2025

Hong Kong Jinlongyu International Co., Ltd.  
Flat/Rm A 12/F ZJ 300  
300 Lockhart Road  
Wan Chai  
Hong Kong  
(Attn.: Mr. Anthony ZHOU)

Dear Sir,

**“Jinlongyu / HILLY / TRICIRCLE ” BS7846 F2 Armoured Fire Resisting Cables**

I refer to your submission of e-application ( Transaction Reference No. FSD0580DQ1S0UMPF ) we received on 3.8.2025 together with copy of BASEC Certificate of Product Approval – Certificate No. 202/002/006 Issue no. 6, product catalogue, with respect to the captioned product for our acceptance assessment.

According to FSD Circular Letter no. 1/2024, any fire service installation/ equipment (except portable equipment, i.e. fire extinguisher, fire blanket, etc.) which is certified and properly listed by one of our recognized Product Certification Bodies (PCBs) is deemed to be accepted by this Department subject to (i) no change of the listing condition; and (ii) such equipment and the installation being in conformity with all relevant local requirements.

The application for the captioned product acceptance by this Department is not required subject to their valid BASEC listing in compliance with BS 7846: 2015 Category F2 as listed in the BASEC product certification scheme and their correct cable markings.

Yours faithfully,

(Stanley CHOW)  
for Director of Fire Services

cc:

Engr (OFFA)3

CTO(FPEC) c/w copy of incoming application form and BASEC Certificate Certificate No. 202/002/006  
Issue no. 6 only for record – Fax 2382 2495