

消防處  
牌照及審批總區  
消防工程合規課  
通風系統組  
香港灣仔告士打道5號稅務大樓35樓



FIRE SERVICES DEPARTMENT  
LICENSING & CERTIFICATION COMMAND  
Fire Protection Engineering Compliance Division  
Ventilating Systems Group  
35/F, Revenue Tower,  
5 Gloucester Road, Wan Chai, Hong Kong

本處檔號 Our Ref.: FSD LC VSG 317/21 - 2026005  
來函檔號 Your Ref.: JLY BS 8592 single core fire cable  
圖文傳真 Fax: (852) 2382 2495  
電話 Tel. No.: (852) 2718 7567  
電郵 E-mail: fsvs@hkfsd.gov.hk

09 February 2026

Hong Kong Jinlongyu International Co., Limited  
Flat/ Rm A 12/F,  
ZJ 300, 300 Lockhart Road,  
Wan Chai  
Hong Kong

(Attn.: Mr. Anthony Zhou)

Dear Sir,

**“Jinlongyu” HILLY® Single Core Fire Resisting Cables**

I refer to your above e-Form submission (Transaction Reference No. FSD0580IVDSGO999) of 25.1.2026 enclosing a set of application form, test certificates/reports and product catalogue, with respect to the captioned product for our acceptance assessment.

According to FSD Circular Letter no. 1/2024, any fire service installation/ equipment (except portable equipment, i.e. fire extinguisher, fire blanket, etc.) which is certified and properly listed by one of our recognized Product Certification Bodies (PCBs) is deemed to be accepted by this Department subject to (i) no change of the listing condition; and (ii) such equipment and the installation being in conformity with all relevant local requirements.

The application for the captioned product acceptance by this Department is not necessary subject to their valid BASEC listing in compliance with current version of BS 6387 : 2013 (Categories C, W & Z) as listed in the BASEC Certificate and their correct cable markings.

Yours faithfully,

(Rumin YIN)  
for Director of Fire Services

cc:  
Engr(OFFA)2  
CTO(FPEC)

RY/jf

FileCode: Jinlongyu HILLY Single Core Fire Resisting Cable\_2026005 (Listed).doc